



# CD/11 oil firing servicing & commissioning report

Plumbing &amp; Heat-

PLEASE COMPLETE ALL THE UNSHADED AREAS

<b>Registered Business Details</b>		<b>Job Address</b>	
Company	<u>Plumbing &amp; Heating Ltd</u>	Name	<u>MR BROOKS</u>
Address	<u>Mullacott Farm</u>	Address	<u>OTTER POOL BARN</u> <u>TWITCHING PARK LANE</u> <u>WEST STOFORD BARTON</u>
	<u>Devon</u>		
Postcode	<u>EX34 8NA</u>	Tel. N°	
Company OFTEC Registration Number	<u>C9816</u>	Postcode	<u>EX34 8PJ</u>
		Tel N°	<u>07970538998</u>
		Reason for attending today <u>BOILER SERVICE</u>	

**Pre-commissioning checks / Legislation**1. Is there a completed CD/10 (or equivalent) for the installation works? **NA**2. If the installer is not a Competent Person, is there a Building Notice? **NA**If **YES**, insert Ref N° here

Appliance Make	<b>GRANT VORTEX</b>	Model	PRO BOILER HOUSE 46/58	Serial N°	195541240316151	
Burner Make	<b>RIELLO</b>	Model	RDB 3.2	Type	PJ	
Tank Material M / P		Bunded? <b>Y</b>	Flue Type	BF/HL	Fuel Type	C2

**Oil firing & commissioning schedule** (Confirm in accordance with OFTEC industry standard checklist and tick as appropriate)

N°	Schedule Item	Checked?	Passed?	Parts fitted / Observations
1	Oil storage	<b>Y</b>	<b>Y</b>	
2	Oil supply system	<b>Y</b>	<b>Y</b>	
3	Air supply	<b>Y</b>	<b>Y</b>	
4	Chimney / flue	<b>Y</b>	<b>Y</b>	
5	Electrical safety	<b>Y</b>	<b>Y</b>	
6	Heat exchanger	<b>Y</b>	<b>Y</b>	
7	Combustion chamber	<b>Y</b>	<b>Y</b>	
8	Pressure jet burner	<b>Y</b>	<b>Y</b>	

9	Vaporising and wallflame burner	-	-	
10	Wallflame burner (additional)	-	-	
11	Appliance safety controls	Y	Y	
<b>Heating System Service</b>		N	-	
12	Controls check	Y	Y	
13	System check—Hot water type	-	-	
14	System check—Warm air type	-	-	

**Important comments** The comments may include advice on remedial work necessary to enable the installation to comply with the requirements of the Building Regulations, Control of Pollution and British Standards

<b>Test results</b> It is important to keep a record of the combustion analysis results—if they have been carried out electronically the printout should be attached to all copies of the service schedule and report		Printout attached?		Y
Pump pressure	9.5 Bar	<b>Efficiency</b>	Net 98.4 %	Gross 88.6 %
Pump vacuum	N/A Bar	<b>Combustion</b>	Smoke 0-1	CO 8 ppm
Draught	mm / WG	<b>Nozzle</b>	Size 1.35	Angle 80 degs
CO <sub>2</sub>	13.1 %	<b>Oil flow rate</b>	Low —	High —
Flue gas temp	66 °C	<b>DHW flow rate</b>	Cold N/A	Hot N/A
			l/min	l/min

Technician's Signature: *J Gardner* Print Name: JOHN GARDNER  
 OFTEC Reg. Number: 27886

